# WRANGELL AIRPORT

## SAND & CHEMICAL STORAGE BUILDING



**LOCATION** 

**NOVEMBER 21, 2001** 

### SHEET INDEX

1 A001 COVER

2 A002 LEGEND, ABBREVIATIONS & SCHEDULES

3 A101 DEMOLITION PLAN

4 A201 FLOOR PLAN

5 A202 ROOF PLAN

6 A301 EXTERIOR ELEVATIONS

7 A302 EXTERIOR ELEVATIONS

8 A303 BUILDING SECTION 9 A304 BUILDING SECTION

10 A305 BUILDING SECTION

11 A401 DETAILS 12 A402 DETAILS

13 A403 DETAILS

14 C101 SITE PLAN

15 C102 WATERLINE PLAN & PROFILE VIEW

16 C103 SITE SECTION & DETAILS

17 C104 CIVIL SCHEMATICS & DETAILS

18 C105 DETAILS

19 C106 DETAILS

20 C107 EROSION & SEDIMENT CONTROL PLAN

21 S001 ABBREVIATIONS & GENERAL NOTES

22 S101 FOUNDATION PLAN & FOOTING SCHEDULE

24 M101 MECHANICAL LEGEND & SCHEDULES

25 M201 MECHANICAL FLOOR PLAN

26 M301 MECHANICAL SCHEMATICS & DETAILS 27 M401 MECHANICAL DETAILS

28 E201 FLOOR PLAN POWER

29 E202 SINGLE LINE DIAGRAM & SCHEDULES


30 E301 FLOOR PLAN LIGHTING

# CONSULTANTS

### **CODE DATA**

2000 IBC **OCCUPANCY S-1 CONSTRUCTION TYPE V-B TABLE 503** STORIES-1 STORY ALLOWED 1 STORY ACTUAL AREA- 9,000SF ALLOWED 10,052SF ACTUAL AREA INCREASE CALCULATION (506.2) If = 100 (  $(\frac{418}{418})$ -.25)  $\frac{30}{30}$ =75 (506.1) A  $a = 9,000 + (9,000 \times \frac{75}{100}) + (9,000 \times \frac{0}{100}) = 15,750$ 

**NOT SPRINKLERED** 



AS BUILTS

CONTRACTOR! MCGRAW'S CUSTOM CONSTRUCTION

PROJECT ENGINEER ; AL RISLEY BEGIN DATE! JUNE 27, 2002 ENO DATE : APRIL 17, 2003

PLANS DEVELOPED BY: **JENSEN YORBA** LOTT INC.

NOTE:

DO NOT SCALE FROM THESE PLANS — USE DEMERSSONS


PATH:	PATH: .						
BY:	DATE:	DESCRI	PTION OF CHANGE:				
			14				
FR	ECOR	D OF	REVISIONS				

STATE OF ALASKA DEPARTMENT OF TRANSPORTATION AND PUBLIC FACILITIES SOUTHEAST REGION

WRANGELL AIRPORT SAND & CHEMICAL STORAGE BUILDING ADDITION

A001 PROJECT NO. 67547 DESIGNED BY: AIP-3-02-0323-0902 DRAWN BY: DATE: NOVEMBER 21, 2001 CHECKED BY: \_o<u>f</u> 30

SHEET 1



106A 110A	YPE A	DOOR MAT	DOOR FIN		FRAME	
110A		:		MAT	FIN	REMARKS
	<u></u>	i				OVERHEAD SECTIONAL 24
1100		HM ;	PT	НМ	PT	
110B	С	НМ	PT	НМ	PT	
112A	A					OVERHEAD SECTIONAL 20
113A	Α					OVERHEAD SECTIONAL 20
114A	В					OVERHEAD SECTIONAL 16
115A	Α					OVERHEAD SECTIONAL 24
106B	<b>C</b>	НМ	PT	HM	PT	

Project As Built Drawings Have Been Reviewed By The Project Engineer & Represent, To The Best Of My Knowledge, The Project As Constructed.

Proj. Eng. 1442 Date 6/9/03

A401

DOOR TYPES A401 16'-0" 24'-0" A401  $\bigcirc$ B A401

ł	
	Jensen Yorba Lott
MAN DOOR SEE ELEV FOR LOCATION	Inc.
MAN DOOR OPEN OUT SAND STORAGE 113	522 West 10th Street Juneau, Alaska 99801 phone 907-586-1070 fax 907-586-3959 jensenyorbalott.com
	NOTE: DO NOT SCALE FROM THESE

PATH: .					
BY:	DATE:	DESCRIPTION OF CHANGE:			
		•			
R	ECOR	D OF REVISIONS			

GALVANIZED

GRAB BAR

GLASS

GYPSUM BOARD

HOLLOW CORE

HOLLOW METAL

**HARDWOOD** 

GBD

 $\mathsf{GL}$ 

GR

PLAS

**PRCST** 

PTD

RESIL

PLASTER

PAPER TOWEL DISPENSER UL

PRESSURE TREATED

QUARRY TILE

ROOF DRAIN

**REFERENCE** 

REINFORCED

REQUIRED

RESILIENT

**RADIUS** 

PAIR

TELEVISION

UNFINISHED

VESTIBULE

WATER CLOSET

WATERPROOF

WASTE RECEPTACLE

WAINSCOT

WIDE

WOOD WITHOUT

TYPICAL

TOP OF WALL

UNDERWRITER LABORATORY

UNLESS OTHERWISE NOTED

CORR

CTR

CTSK

DEPT

DS

CORRIDOR

CERAMIC TILE

COUNTERSUNK

DEPARTMENT

DRINKING FOUNTAIN

CARPET

CENTER

DOUBLE

DIAMETER

DIMENSION

DISPENSER


**DOWNSPOUT** 


DOOR OPENING


STATE OF ALASKA DEPARTMENT OF TRANSPORTATION AND PUBLIC FACILITIES SOUTHEAST REGION


WRANGELL AIRPORT SAND & CHEMICAL STORAGE BUILDING ADDITION

	A002  PROJECT NO. 67547  AIP-3-02-0323-0902  DATE:  NOVEMBER 21, 2001		
DESIGNED BY:			
DRAWN BY:			
CHECKED BY:	SHEET 2 or 30		









Jensen Yorba Lott Inc. 522 West 10th Street

Juneau, Alaska 99801 phone 907-586-1070 fax 907-586-3959 jensenyorbalott.com Project As Built Drawings Have Been
Reviewed By The Project Engineer &
Represent, To The Best Of My Knowledge,
The Project As Constructed.

Proj. Eng. Date 6/9/03


NOTE: DO NOT SCALE FROM THESE PLANS - USE DIMENSIONS

 A101
PROJECT NO. 67547 AIP-3-02-0323-0902
DATE:


<b>:</b> .			
	DATE:	DESCRIPTION OF CHANGE:	STATE OF ALASKA
			DEPARTMENT OF TRANSPORTATION
			AND PUBLIC FACILITIES
王多	CORD	OF REVISIONS	SOUTHEAST REGION

DESIGNED BY: WRANGELL AIRPORT DRAWN BY: SAND & CHEMICAL STORAGE BUILDING ADDITION CHECKED BY:

NOVEMBER 21, 2001




\0029\Arch CD's\A201.dwg, 02/01/02 01:53:28 PM, HP Designlet 500 42 +HPGL 2 Card



SOUTHEAST REGION


RECORD

REVISIONS




RECORD

OF REVISIONS



6:\CAD\0029\Arch CD's\A302.dwg, 02/01/02 01:52:59 PM, HP Designlet 500 42 +HPGL2 Card.pc3



Project As Built Drawings Have Been Reviewed By The Project Engineer & Represent, To The Best Of My Knowledge, The Project As Constructed.

Proj. Eng. Date 6903

Lott
Inc.

522 West 10th Street
Juneau, Alaska 99801
phone 907-586-1070
fax 907-586-3959
jensenyorbalott.com

NOTE:

DO NOT SCALE FROM THESE PLANS - USE DIMENSSORS

PATE: .


BY: DATE: DESCRIPTION OF CHANGE:

RECORD OF REVISIONS

STATE OF ALASKA
DEPARTMENT OF TRANSPORTATION
AND PUBLIC FACILITIES
SOUTHEAST REGION


WRANGELL AIRPORT
SAND & CHEMICAL STORAGE BUILDING ADDITION

·	A303
DESIGNED BY:	PROJECT NO. 67547 AIP-3-02-0323-0902
DRAWN BY:	DATE: NOVEMBER 21, 2001
CHECKED BY:	SHEET 8 OF 30



1 BUILDING SECTION

SCALE: 0 2' 4' 8'



Jensen Yorba Lott

522 West 10th Street Juneau, Alaska 99801 phone 907-586-1070 fax 907-586-3959 jensenyorbalott.com

NOTE:

DO NOT SCALE FROM THESE PLANS - USE DEMENSIONS

PATE: .

BY: DATE: DESCRIPTION OF CHANGE:


RECORD OF REVISIONS

STATE OF ALASKA
DEPARTMENT OF TRANSPORTATION
AND PUBLIC FACILITIES
SOUTHEAST REGION


WRANGELL AIRPORT
SAND & CHEMICAL STORAGE BUILDING ADDITION

Project As Built Drawings Have Been
Reviewed By The Project Engineer &
Represent, To The Best Of My Knowledge,
The Project As Constructed.


Proj. Eng. Date 6/9/03




versize: Custom 1: 33.6 x 20.68 in. (landscape)





RECORD





G:\CAD\0029\Arch CD's\A401.dwg, 02/01/02 01:52:21 PM, HP Designlet 500 42+HPGL2
























CROSS CAP OR PLI		<u>ug</u>		VALVE		
PIPE SIZE	90° BEND, TEE OR PLUG		0° – 45° BEND OR CROSS		VALVES	
	MIN. CONCRETE VOLUME (YD <sup>3</sup> )	MIN. BEARING AREA (FT <sup>2</sup> )	MIN. CONCRETE VOLUME (YD <sup>3</sup> )	MIN. BEARING AREA (FT <sup>2</sup> )	MIN. CONCRETE VOLUME (YD <sup>3</sup> )	
6"	0.3	3.0	0.25	1.6	0.25	
8*	0.5	5.3	0.3	3.0	0.5	
12"	1.0	12.0	0.75	6.5	0.5	

- 1. CENTER OF MASS OF THRUST BLOCK MUST LAY OPPOSITE TO AND ALIGNED AGAINST THE DIRECTION OF THRUST.
- 2. THRUST BLOCKS SHALL BE POURED SO THAT JOINTS OF FITTINGS REMAIN ACCESSIBLE.
- 3. CONCRETE THRUST BLOCKS SHALL BE POURED AGAINST UNDISTURBED EARTH. UNSTABLE OR UNSUITABLE MATERIALS SHALL BE REMOVED, REPLACED AND/OR COMPACTED AS DETERMINED BY THE ENGINEER.
- 4. VOLUME AND BEARING SURFACE OF 2500 P.S.I. CONCRETE THRUST BLOCKS ARE BASED ON 150 P.S.I. WATER PRESSURE AND SOIL BEARING CAPACITY OF 2000 P.S.F. ALL OTHER PRESSURE AND/OR SOIL CONDITIONS ARE SUBJECT TO THE ENGINEER'S REVIEW AND APPROVAL.





NOMINAL 2:1 CUT OR FILL

SLOPES FROM EDGE OF PAD

VALVE BOX

--- HYDRANT ACCESS PAD

- SELECT BORROW

- 6" BASE COURSE GRADING D-1


SELECT EMBANKMENT AND/OR


ALTERNATIVE

LOCATION SHOWN

·18" DIA (MIN) DRAINAGE CULVERT

SHOULDER OF UNPAVED ROAD OR EDGE OF PAVEMENT





Project As Built Drawings Have Been

The Project As Constructed.

Reviewed By The Project Engineer & Represent, To The Best Of My Knowledge,

Proj. Eng. AMT. Date 6/9/03

ensen

522 West 10th Street

phone 907-586-1070

jensenvorbalott.com

Architecture • Engineering

Land Surveying • Planning

DO NOT SCALE FROM THESE


NOTE:

fax 907-586-3959

Juneau, Alaska 99801

Yorba

Lott



1. HYDRANT BARREL SHALL BE PLUMB.


RECORD

- 2. WATER PIPE SHALL BE 6" D.I.P. CONNECTIONS SHALL BE RESTRAINED MECHANICAL JOINTS OR MEGALUGS.
- 3. GROUND COVER SHALL BE 5' MINIMUM.
- 4. BENDS BETWEEN THE HYDRANT AND THE MAIN SHALL NOT EXCEED 11 1/4".

FIRE HYDRANT

- 5. ALL HYDRANTS SHALL BE PAINTED "CATERPILLER YELLOW". ALL HYDRANTS WITH PLUGGED DRAINS SHALL HAVE THE TOP BONNET PAINTED OSHA SAFETY BLUE. NUMBER OF FEET TO VALVE SHALL BE PRINTED IN BLACK 1/2" BLOCK LETTERS JUST BELOW TOP BONNET.
- 6. THAW WIRE AND CONTINUITY STRAPS SHALL BE #2 COPPER WITH TYPE THHW INSULATION. THAW WIRE SHALL BE CADWELDED TO THE MAIN. EACH JOINT SHALL HAVE TWO CADWELDED CONTINUITY STRAPS ACROSS OPPOSITE SIDES OF THE PIPE.


REVISIONS



- DRAINAGE CULVERT -DITCH FLOW LINE -INSULATION D HYDRANT LEG ----SECTION A-A **ELEVATION VIEW** 1. WHEN DITCH IS LESS THAN 18" DEEP, USE OPEN DITCH IN LIEU OF CULVERT 2. FROM EDGE OF ROAD TO DITCH LINE, SLOPE SURFACE OF HYDRANT PAD TO MATCH EXTENSION OF ROADWAY CROWN. 3. TOPSOIL AND SEED SIDE SLOPES. FIRE HYDRANT ACCESS PAD C106 SCALE: N.T.S.

-- 8' MIN.---

PLAN VIEW



**ELEVATION VIEW** 

1. GUARD POSTS SHALL BE 4" DIAMETER, SCHEDULE 40 STEEL PIPE. 2. POSTS SHALL BE FILLED FLUSH WITH CONCRETE AND PAINTED WITH OSHA YELLOW ENAMEL AFTER

DESIGNED BY:

- 3. POSTS SHALL NOT BLOCK OPERATION OF VALVE.
- 4. GUARD POSTS SHALL NOT BE INSTALLED WHEN THE FIRE HYDRANT IS LESS THAN 32' FROM THE ROAD CENTERLINE.

C106 PROJECT NO. 67547 AIP 3-02-0323-0902

PLANS - USE DIMENSIONS 49 TH

FIRE HYDRANT GUARD POSTS C106 SCALE: N.T.S.

> DRAWN BY: DATE: CB NOVEMBER 21, 2001 CHECKED BY: SHEET 19 OF 30

PATH:

OF

STATE OF ALASKA DEPARTMENT OF TRANSPORTATION AND PUBLIC FACILITIES SOUTHEAST REGION

HYDRANT ACCESS PAD -

G GUARD POSTS -


2" MIN., 3" MAX. BETWEEN FLANGE

AND BASE COURSE

2:1 SLOPE FROM EDGE -

OF SHOULDER

WRANGELL AIRPORT SAND & CHEMICAL STORAGE BUILDING ADDITION



STRUCTURAL ABBREVIATIONS					
ANCHOR BOLT AND ANGLE ARCHITECTURAL	A.B. & L ARCH	LONG LEG HORIZONTAL LONG LEG VERTICAL LONG SLOTTED HOLE LONG SPAN	LLH LLV LSH LH		
BASE PLATE BEARING	© B.P. BRG	MANUFACTURER MAXIMUM MECHANICAL MINIMUM	MFR MAX MECH MIN		
BOTTOM  CANTILEVER CAST—IN—PLACE CENTER LINE CHANNEL CLEAR	BOT CANT C.I.P. CL OR & C	NEAR FACE NEAR SIDE NOT TO SCALE NUMBER	N.F. N.S. N.T.S. N OR #		
CHANNEL CLEAR CONCRETE CONCRETE MASONRY UNIT CONNECTION CONSTRUCTION	CLR CONC C.M.U. CONN CONST	ON CENTER OPENING OPPOSITE OPPOSITE HAND	O.C. OPNG OPP O.H.		
CONTINUOUS CONSTRUCTION JOINT CROSS DEAD LOAD	CONT C.J. X- D.L.	PARALLAM STRAND LUMBER PLATE PLYWOOD POUNDS POUNDS PER SQUARE FOOT	PSL PL OR PLYWD P LBS		
DIAMETER DOWN	DIA OR Ø DN	POUNDS PER SQUARE INCH RADIUS	PSF PSI R		
EACH EACH FACE EACH WAY ELECTRICAL	EA E.F. E.W. ELEC	REFERENCE REINFORCING REQUIRED	REF REINF REQ'D.		
ELEVATION EMBEDDED EQUAL EXISTING EXPANSION EXTERIOR	EL EMBED EQ EXIST EXP EXT	SHORT SLOTTED HOLE SIMILAR SLAB JOINT SPECIFICATIONS SQUARE STANDARD STEEL	\$SH \$IM \$J \$PECS \$Q \$TD \$TL		
FAR FACE FAR SIDE FIRE RESISTANT FLOOR FOOT	F.F. F.S. F.R.T.P. FLR FT	TRANSVERSE TOP TOP AND BOTTOM TOP OF CONCRETE TOP OF FOOTING	TRANS T/ T&B TOC TOF		
GAUGE GLUE LAM BEAM	GA GLB	TOP OF FOOTING TOP OF STEEL TUBE STEEL TYPICAL	TOS TS TYP		
HEADED ANCHOR STUD HIGH STRENGTH HOLLOW STRUCTURAL SECTION HORIZONTAL	H.A.S. H.S. HSS HORIZ	UNLESS NOTED OTHERWISE VERIFY IN FIELD	U.N.O. V.I.F.		
INTERIOR	INT	VERTICAL	VERT		
JOINT	JT	WELDED WIRE FABRIC WIDE FLANGE	W.W.F. WF		
KIP	к	WIDE FLANGE TEE WITH	WT W/		
SEE ALSO THE ABBREVIATIONS LISTED ON THE ARCHITECTURAL DRAWINGS					

### GENERAL STRUCTURAL NOTES (APPLIES UNLESS NOTED OTHERWISE)

#### CODE

INTERNATIONAL BUILDING CODE 2000 (IBC 2000).

#### DESIGN LOADS:

OUND SNOW LOAD — 60 PSF MINIMUM FLAT ROOF SNOW LOAD — 50 PSF IMPORTANCE FACTOR — 1.0	SEISMIC USE GROUP:  SEISMIC USE GROUP
ID LOADS:	S1 ————————————————————————————————————
BASIC WIND SPEED 120 MPH EXPOSURE C	INCLUDE 25% OF THE ROOF SNOW LOAD AS
IMPORTANCE FACTOR 1.00	SEISMIC DEAD LOAD

#### **FOUNDATIONS:**

GEOTECHNICAL CONSULTANT: ———— GEOTECHNICAL INVESTIGATION FOR THE WRANGELL SAND & CHEMICAL STORAGE BUILDING, PROJECT NO. 67547, PREPARED BY MITCH McDONALD, ENGINEERING GEOLOGIST, STATE OF ALASKA, DEPARTMENT OF

TRANSPORTATION & PUBLIC FACILITIES, DATED APRIL 12, 2000.

ASSUMED SOIL BEARING = 2,000 PSF. REFER TO THE CIVIL DRAWINGS FOR EXCAVATION, SUBGRADE PREPARATION AND BACKFILL RECHIREMENTS

THE FOUNDATION PLAN AND DETAILS ARE PRESENTED FOR BIDDING PURPOSES AND MAY NEED TO BE ALTERED TO ACCOMMODATE THE CONTRACTOR'S PROPOSED BUILDING SYSTEM. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE FOOTING SIZE, FOOTING LOCATIONS, PILASTER SIZES, REINFORCING DETAILS, COLUMN LOCATIONS AND ANCHOR BOLT LAYOUTS TO CONFORM TO THE ACTUAL DETAILS OF THE METAL BUILDING SYSTEM BEING PROVIDED. ALL ALTERATIONS REQUIRED FOR THE FOUNDATION SYSTEM SHALL BEAR THE SEAL OF AN ENGINEER REGISTERED IN THE STATE OF ALASKA AND BE SUBMITTED TO THE STATE OF ALASKA PROJECT MANAGER FOR APPROVAL PRIOR TO COMMENCING CONSTRUCTION.

#### CONCRETE:

TYPICAL CONCRETE COMPRESSIVE STRENGTHS				
CONCRETE	MINIMUM 28 DAY COMPRESSIVE STRENGTH	SLUMP AT PLACEMENT		
UNLESS NOTED OTHERWISE, ALL CONCRETE	SHALL BE 3,000 PSI 4	1/2" MAXIMUM		

CONCRETE WORK SHALL CONFORM TO ALL REQUIREMENTS OF ACI 301, "SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDINGS" AND ACI 318, "BUILDING CODE REQUIREMENTS FOR REINFORCED CONCRETE".

CONCRETE CONTAINING SUPERPLASTICIZING ADMIXTURE SHALL HAVE A SLUMP NOT EXCEEDING 3", TO BE FIELD VERIFIED, PRIOR TO ADDING ADMIXTURE, AND NOT EXCEEDING 8" AT PLACEMENT.

ADDITION OF WATER TO THE BATCH FOR MATERIAL WITH INSUFFICIENT SLUMP WILL NOT BE PERMITTED.

MECHANICALLY VIBRATE ALL CONCRETE WHEN PLACED, EXCEPT SLABS ON GRADE. UNLESS APPROVED OTHERWISE IN WRITING BY THE ENGINEER, ALL CONCRETE SLABS ON GRADE SHALL BE BONDED BY CONSTRUCTION JOINTS, KEYED OR SAW CUT, SUCH THAT THE ENCLOSED AREA DOES NOT EXCEED 400 SQUARE FEET. KEYED CONSTRUCTION JOINTS NEED ONLY OCCUR AT EXPOSED EDGES DURING POURING. ALL OTHER JOINTS MAY BE SAW CUT.

### REINFORCING:

	TYPICAL REINFORCING BAR STRENGTHS
OR LARGER	ASTM A615 (GR60) DEFORMED

#### 

#### LAP SPLICES IN CONCRETE:

UNLESS NOTED OTHERWISE, LAP SPLICES IN CONCRETE BEAMS, WALLS, AND SLABS SHALL BE CLASS "B" TENSION LAP SPLICES PER LATEST EDITION OF ACI 318. STAGGER ALTERNATE SPLICES A MINIMUM OF ONE LAP LENGTH.

ALL SPLICE LOCATIONS SUBJECT TO APPROVAL. PROVED BENT CORNER BARS TO MATCH AND LAP WITH HORIZONTAL BARS AT CORNERS AND INTERSECTIONS OF FOOTINGS AND WALLS. REINFORCING BAR SPACINGS GIVEN ARE MAXIMUM ON CENTERS (O.C.). ALL BARS PER CRSI SPECIFICATIONS AND HANDBOOK. DOWEL ALL VERTICAL REINFORCING TO FOUNDATION. SECURELY TIE ALL BARS IN LOCATION BEFORE PLACING CONCRETE. CONCRETE COLUMN DOWEL EMBEDMENT SHALL BE A STANDARD COMPRESSION DOWEL EMBEDMENT LENGTH ACCORDING TO THE LATEST EDITION OF ACI 318.

### SHOP DRAWINGS:

THE CONTRACTOR SHALL REVIEW, STAMP WITH HIS APPROVAL, DATE, AND SIGN ALL SHOP DRAWINGS REQUIRED BY THE CONTRACT DOCUMENTS PRIOR TO SUBMITTING TO THE ENGINEER. AT THE TIME OF SUBMISSION, THE CONTRACTOR SHALL INFORM THE ENGINEER IN WRITING OF ANY DEVIATION IN THE SHOP DRAWINGS FROM THE REQUIREMENTS OF THE CONTRACT DOCUMENTS.

#### SPECIAL INSPECTIONS:

SPECIAL INSPECTION IS REQUIRED DURING THE FOLLOWING OPERATIONS PER IBC SECTION 1705:

<u>CONCRETE</u>: DURING TAKING OF SPECIMENS AND PLACEMENT OF ALL CONCRETE. SEE PROJECT SPECIFICATIONS FOR FREQUENCY OF TESTING AND STRENGTH REQUIREMENTS.

BOLTS INSTALLED IN CONCRETE: PRIOR TO AND DURING THE PLACEMENT OF CONCRETE AROUND BOLTS.

<u>REINFORCING STEFL: DURING PLACEMENT OF REINFORCING STEEL AND CONTINUOUS SPECIAL INSPECTION DURING THE INSTALLATION OF MECHANICAL REINFORCING COUPLINGS.</u>

WELDING: DURING ALL STRUCTURAL WELDING, INCLUDING WELDING OF REINFORCING STEEL.

HIGH STRENGTH BOLTING: WHILE THE WORK IS IN PROGRESS, THE SPECIAL INSPECTOR SHALL DETERMINE THAT THE REQUIREMENTS FOR BOLTS, NUTS, WASHERS, AND PAINT; BOLTED PARTS; AND INSTALLATION AND TIGHTENING ARE MET.

#### DUTIES AND RESPONSIBILITIES OF THE SPECIAL INSPECTOR:

1. THE SPECIAL INSPECTOR SHALL OBSERVE THE WORK ASSIGNED TO BE CERTAIN IT CONFORMS WITH THE APPROVED DESIGN DRAWINGS AND SPECIFICATIONS.

2. THE SPECIAL INSPECTOR SHALL FURNISH INSPECTION REPORTS TO THE STATE OF ALASKA PROJECT MANAGER AND TO THE ENGINEER OR ARCHITECT OF RECORD. ALL DISCREPANCIES SHALL BE BROUGHT TO THE IMMEDIATE ATTENTION OF THE CONTRACTOR FOR CORRECTION.

3. UPON COMPLETION OF THE ASSIGNED WORK, THE SPECIAL INSPECTOR SHALL COMPLETE AND SIGN A FINAL REPORT CERTIFYING THAT TO THE BEST OF HIS KNOWLEDGE, THE WORK IS IN CONFORMANCE WITH THE APPROVED PLANS AND SPECIFICATIONS, AND THE APPLICABLE WORKMANSHIP PROVISIONS OF THE CODE.

#### STRUCTURAL OBSERVATION:

THE OWNER SHALL EMPLOY THE ENGINEER RESPONSIBLE FOR THE STRUCTURAL DESIGN TO PERFORM THE STRUCTURAL OBSERVATION AS DEFINED IN THE IBC. OBSERVED DEFICIENCIES SHALL BE REPORTED IN WRITING TO THE OWNER'S REPRESENTATIVE, SPECIAL INSPECTOR, CONTRACTOR, AND THE BUILDING OFFICIAL. THE STRUCTURAL OBSERVER SHALL SUBMIT TO THE BUILDING OFFICIAL A WRITTEN STATEMENT THAT THE SITE VISITS HAVE BEEN MADE AND IDENTIFYING ANY REPORTED DEFICIENCIES THAT, TO THE BEST OF THE STRUCTURAL OBSERVER'S KNOWLEDGE, HAVE NOT BEEN RESOLVED.

#### GENERAL:

THE CONTRACT STRUCTURAL DRAWINGS AND SPECIFICATIONS REPRESENT THE FINISHED STRUCTURE. THEY DO NOT INDICATE THE METHOD OF CONSTRUCTION. THE CONTRACTOR SHALL PROVIDE ALL MEASURES NECESSARY TO PROTECT THE STRUCTURE DURING CONSTRUCTION. SUCH MEASURES SHALL INCLUDE, BUT NOT BE LIMITED TO, BRACING, SHORING FOR LOADS DUE TO CONSTRUCTION EQUIPMENT, ETC. OBSERVATION VISITS TO THE SITE BY THE STRUCTURAL ENGINEER SHALL NOT INCLUDE INSPECTION OF THE ABOVE ITEMS.

WHERE REFERENCE IS MADE TO VARIOUS TEST STANDARDS FOR MATERIALS, SUCH STANDARDS SHALL BE THE LATEST EDITION AND/OR ADDENDUM.

ESTABLISH AND VERIFY ALL OPENINGS AND INSERTS FOR ARCHITECTURAL AND ELECTRICAL WITH APPROPRIATE TRADES, DRAWINGS, AND SUBCONTRACTORS PRIOR TO CONSTRUCTION. DO NOT PENETRATE ANY STRUCTURAL ELEMENTS (FOOTINGS, TENSION TIES OR PILASTERS) WITHOUT PRIOR WRITTEN APPROVAL OF THE STRUCTURAL ENGINEER.


CONTRACTOR SHALL BE RESPONSIBLE FOR ALL CHANGES IN DETAILING NECESSARY IF PRODUCTS OTHER THAN THOSE SPECIFIED ON THE DRAWINGS ARE USED.

NOTES AND DETAILS ON DRAWINGS SHALL TAKE PRECEDENCE OVER GENERAL STRUCTURAL NOTES AND TYPICAL DETAILS. WHERE NO SPECIFIC DETAILS ARE SHOWN, CONSTRUCTION SHALL CONFORM TO SIMILAR WORK ON THE PROJECT.

WHERE ANY DISCREPANCIES OCCUR BETWEEN PLANS, DETAILS, GENERAL STRUCTURAL NOTES, AND SPECIFICATIONS, THE GREATER REQUIREMENTS SHALL GOVERN.

ANY ENGINEERING DESIGN PROVIDED BY OTHERS AND SUBMITTED FOR REVIEW, INCLUDING CHANGES TO THE FOUNDATION PLAN REQUIRED TO ACCEPT THE BUILDING SYSTEM, SHALL BEAR THE SEAL OF A CIVIL ENGINEER REGISTERED IN THE STATE OF ALASKA.





Yorba Lott

Inc.

522 West 10th Street Juneau, Alaska 99801 phone 907-586-1070 fax 907-586-3959 jensenyorbalott.com

NOTE:

DO NOT SCALE FROM THESE PLANS - USE DIMENSIONS

PATH: .

BY: DATE: DESCRIPTION OF CHANGE:

X XX/XX/XX

X XX/XX/XX

X XX/XX/XX

X EXCORD OF REVISIONS

STATE OF ALASKA
DEPARTMENT OF TRANSPORTATION
AND PUBLIC FACILITIES
SOUTHEAST REGION


WRANGELL AIRPORT
SAND & CHEMICAL STORAGE BUILDING ADDITION


	S001
DESIGNED BY:	PROJECT NO. 6754 AIP NO. 3-02-0323-090
DRAWN BY:	DATE: November 21, 200.
CHECKED BY:	SHEET 21 OF 30

Project As Built Drawings Have Been Reviewed By The Project Engineer &

The Project As Constructed.

Represent, To The Best Of My Knowledge.






KEY NOTES

- 6" CONCRETE SLAB ON GRADE W/ #4 AT 12" O.C. EACH WAY, CENTERED IN SLAB. TOP OF SLAB ELEVATION AS INDICATED ON PLAN. TREAT WITH CURING/SEALING COMPOUND ONLY.
- 8" CONCRETE SLAB ON GRADE W/ #5 AT 12" O.C. EACH WAY, CENTERED IN SLAB. REPLACE 15% OF THE PORTLAND ASH- TOP OF SLAB ELEVATION AS INDICATED ON PLAN. TREAT SURFACE OF SLAB WITH SILICATE PENETRATING LIQUID FLOOR TREATMENT PER MANUFACTURER'S RECOMMENDATIONS.
- DO NOT DOWEL NEW FOOTING OR SLAB TO EXISTING.
- RE-FRAME END WALL FOR NEW OPENING.
- REFER TO THE MECHANICAL DRAWINGS FOR HOUSEKEEPING PAD SIZE AND LOCATION. REINFORCE THE PAD WITH 4X4 W1.4 X W1.4 WWF
- 6 SJ—SJ INDICATES A SAWN CONTRACTION JOINT IN THE SLAB. DISCONTINUE THE REINFORCING THROUGH THE JOINT, SEAL THE JOINT WITH A URETHANE JOINT FILLER AFTER THE SLABS HAVE CURED.

	F(	MITOC	G (F) SCHEDULE	
3° CLR ( Th	3	· · · · · · · · · · · · · · · · · · ·	FOR CONSTRUCT FOOTINGS, SEE  FOOTING REINFO SHOWN IN SCHE	DETAILS.  RCING AS
MARK	FOOTING DIMENS		FOOTING REINFORCING	REMARKS
	SIZE	<b>"H"</b>		
F1	10'-0" X 14'-0"	<b>36</b> °	#6 AT 12" EACH WAY TOP AND BOTTOM	TOP FOOTING ELEV.=108.96
F2	4'-6" X CONT.	20*	SEE 3/S201	TOP FOOTING ELEV.=108.96
F3	20" X CONT.	10"	(2) #5 CONT.	TOP FOOTING ELEV.=108.29
F4	6'-0" X 6'-0"	16*	(6) #5 EACH WAY, BOTTOM ONLY	TOP FOOTING ELEV.=108.29
F5	4'-0" X 4'-0"	12*	(4) #4 EACH WAY, BOTTOM ONLY	TOP FOOTING ELEV.=107.96



NOTE: SOUTH END WALL FRAMING ELEVATION SHOWN, NORTH END WALL SIMILAR

END WALL FRAMING SCALE: N.T.S.


Project As Built Drawings Have Been Reviewed By The Project Engineer & Represent, To The Best Of My Knowledge, The Project As Constructed.

NOTE: DO NOT SCALE FROM THESE PLANS - USE DIMENSIONS

PATH: . AND PUBLIC FACILITIES XX/XX/XX SOUTHEAST REGION RECORD OF REVISIONS

SAND & CHEMICAL STORAGE BUILDING ADDITION

**S101** DESIGNED BY: PROJECT NO. 67547 AIP NO. 3-02-0323-0002 DRAWN BY: DATE: November 21, 2001 CHECKED BY: SHEET 22 OF 30



Jensen


522 West 10th Street Juneau, Alaska 99801

phone 907-586-1070 fax 907-586-3959

jensenyorbalott.com

Yorba

Lott



DESIGNATION	EQUIPMENT	LOCATION	DESCRIPTION	ELECTRICAL		
LG-1	LEVEL GAGE	T-1		HP. VOLTS, PHASE	BASIS OF DESIGN (MANUFACTURER, MODEL)	NOTES
LG-2	LEVEL GAGE	T-2	SIZE TO MATCH TANK		INFERNO MODEL ATS	_
TM-1			SIZE TO MATCH TANK	-	INFERNO MODEL ATS	
	PROPELLER MIXER	T-1	425 RPM, 12" TURBINE	3, 208, 3	GROVAC, MODEL 700-3000-GD-ED	
BU-1	BULK BAG UNLOADER	T-1	TO MATCH UREA BULK BAGS		AUTOMATED FLEXIBLE CONVEYOR	
HO-1	HOPPER	BU-1	TO MATCH UREA BULK BAGS	_		
TV-1	TEMPERATURE REGULATOR	T-1	60 GPM, 22 PSI DROP, 1"		AUTOMATED FLEXIBLE CONVEYOR	2
			or or my 22 for bhor, i	_	POWERS MODEL 11WM THERMAL SYSTEM 700-C15AI02	_
BFP-1, 2	BACKFLOW PREVENTER	T-1	60 GPM, 2" SIZE	_		
BM-1	BAG MASSAGER	BU-1	80 PSI, 2 CFM±- AIR	0.400	WATTS SERIES 909 BB	<del>-</del>
AG-1	AGITATOR	HOPPER		0, 120, 1	AUTOMATED FLEXIBLE CONVEYOR	-
OWS-1		HOPPER	COMPATIBLE W/ UREA PELLETS	1.5, 208, 3	AUTOMATED FLEXIBLE CONVEYOR	
	OIL-WATER SEPARATOR	_	40 GPM, 53 GALLON	_	ANCHORAGE TANK ATLLS40	7
AS-1	AIR SCOOP	AS-1	_	-		3
ET-1	EXPANSION TANK	ET-1	7.6 GAL/2.4 GAL ACCEPT		AMTROL 2"	_
TH-1	TANK HEATER	THE STAY ZIT OF ACCEPT		-	AMTROL EXTROL MODEL 60	_
OTES:		1-1	20 GPM, 155,000 BTUH	_	ARMSTRONG IMMERSION TYPE FHS	

1. GEAR DRIVE FLANGE MOUNTED, SS SHAFT, TURBINE AND HOUSING. 2. PROVIDE GRATE WITH AGITATOR, SEE AG-1.

3. PROVIDE INTEGRAL UPSTREAM SAND TRAP AND EXTENSIONS AS NEEDED TO MEET DEPTH REQUIREMENT.


DECIONATION	T	<del></del>				PUM	P SCHE	DULE					
DESIGNATION	SERVICE	GPM	HEAD (FT)	FLUID	BODY	RPM	SUCTION	DISCHARGE		ELECTRICAL		BASIS OF DESIGN	NOTE
00 4.0	<u> </u>	·	(11)				SIZE	SIZE	HP	VOLTS	PHASE	(MFR & MODEL)	NOTE
CP-1,2	UREA CIRC	400	30	UREA/WATER	STAINLESS	1750	3*	3*	7.5	208	3	G&L PUMP, TRASH HOG II, MODEL 3DTH23EL	
CP-3	HW CIRC	60	30	WATER	BRONZE		4 4 4 5					SALE FOMP, TRASH FIGG II, MODEL 3DTH23EL	_
		<del> </del>		WAIEK	BRUNZE		1-1/2"	1-1/2"	3/4	120	1	GRUNDFOS, MODEL UPS40-160	
OP-1	FUEL OIL	30 GPH	200	FUEL OIL	BRONZE	-	3/4"	3/4"	1/4	100			
		<u> </u>		<u> </u>				J 3/ 4	1/4	120	1 1	MODINE (WEBSTER SPM-30-1)	_

DESIGNATION	LOCATION	SERVICE	CFM	PDM	CD *	FAN SCH NOISE CRITERIA	ELECTRICAL	WEIALL		
EF-1				<del>                                     </del>	SP "w.g.		HP. VOLTS. PHASE	WEIGHT LBS	BASIS OF DESIGN (MANUFACTURER, MODEL)	NOTES
	114	AREA EXHAUST	10,000	860	.25	33	1, 208, 3	290	GREENHECK S2-30-625-C10	110123
CF-1,2	111, 114	CEILING	27500	_						-
NOTES:				Ĺ			160W, 120, 1	24	LEADING EDGE 5600-1	

1. PROVIDE VFD. CONTRACTOR SHALL ENSURE COMPATIBILITY BETWEEN FAN MOTOR AND VFD.

			OIL FIRED EQUIPMENT	SCHEDULE			
DESIGNATION	EQUIPMENT	LOCATION	DESCRIPTION	ELECTRICAL	WEIGHT		<b></b>
WH-1	OIL-FIRED WATER HEATER	111	192 GAL, 1,286 GPH RECOVERY 90 DEG RISE	HP. VOLTS, PHASE 0.25, 120, 1	LBS	BASIS OF DESIGN (MANUFACTURER, MODEL)	NOTES
UH-1,2,3,4	OIL-FIRED UNIT HEATER	111, 114	185,000 BTUH OUTPUT		4300	BOCK MODEL 200E-1150	_
			TOOLOGO BIOLI OOLFOL	0.33, 120, 1	398	MODINE MODEL POH185	_

	1AT	NK SCHEDU	LE	
DESIGNATION	EQUIPMENT	CAPACITY (GAL)	BASIS OF DESIGN (MFR & MODEL)	NOTES
T-1	UREA MIXING TANK	4000	GREER	_
T-2	UREA STORAGE TANK	12,000	GREER	
T-3	OWS-1 EFFLUENT TANK	1,000	GREER	




V

Jensen Yorba Lott

522 West 10th Street Juneau, Alaska 99801 phone 907-586-1070 fax 907-586-3959 jensenvorbalott.com

NOTE:

DO NOT SCALE FROM THESE PLANS - USE DIMENSIONS



PATH: DATE: DESCRIPTION OF CHANGE: RECORD REVISIONS 

STATE OF ALASKA DEPARTMENT OF TRANSPORTATION AND PUBLIC FACILITIES SOUTHEAST REGION


WRANGELL AIRPORT SAND & CHEMICAL STORAGE BUILDING ADDITION


M101DESIGNED BY: PROJECT NO. 67547 AIP 3-02-0323-0902 DRAWN BY: LDS November 21, 2001 CHECKED BY: SHEET 24 OF 30 HBR


Represent, To The Best Of My Knowledge,


Proj. Eng. MHZ Date 4/03


The Project As Constructed.













TRENCH DRAIN CATCH BASIN DETAIL NOT TO SCALE


**VENT THROUGH WALL DETAIL** 



**OUTSIDE AIR INTAKE DETAIL** 



**NEW EXHAUST FAN DETAIL** 



Project As Built Drawings Have Been Reviewed By The Project Engineer & Represent, To The Best Of My Knowledge, The Project As Constructed. UNIT HEATER DETAIL Proj. Eng 11112 Date 6/9/03

Lott 522 West 10th Street Juneau, Alaska 99801 phone 907-586-1070 fax 907-586-3959 jensenyorbalott.com

> DO NOT SCALE FROM THESE PLANS - USE DIMENSIONS

Jensen

Yorba

DATE: DESCRIPTION OF CHANGE: RECORD REVISIONS


STATE OF ALASKA DEPARTMENT OF TRANSPORTATION AND PUBLIC FACILITIES SOUTHEAST REGION

WRANGELL AIRPORT SAND & CHEMICAL STORAGE BUILDING ADDITION

M401 DESIGNED BY: PROJECT NO. **67547** AIP **3-02-0323-0902** DRAWN BY: November 21, 2001 CHECKED BY: SHEET 27 OF 30

HBR






	PANEL-L	SIZE			S/PHAS			MAIN	LOCATION	TNUON
	· · · · · · · · · · · · · · · · · · ·	225 AM	PS	120/2	08V, 3	PH	LU	GS ONLY	VEHICLE BAY 115 S	URFACE
C <sub>K</sub>	DESCRIPTION	BREAKER AMP/			KVA		<del>,</del>	BREAKER AMP/	DESCRIPTION	c <sub>K</sub> _
NO	l e e e e e e e e e e e e e e e e e e e	POLÉ	CKT	AØ	BØ	CØ	CKT	POLÉ		NO
1	EAST WALL LTG	20/1 *	0.9	1.6			0.7	20/1 GFI	MIXING STORAGE 111	Ø 2
3	CENTER HIBAY	20/1 *	1.9		2.8		0.9	20/1 GFI	VEHICLE BAY 115	4
5	CENTER HIBAY	20/1 *	1.9			2.8	0.9	20/1	EXTERIOR	6
7	WEST WALL	20/1 *	1.3	4.2			2.9	50/3	CP-1 (7.5 HP)	8
9	EXTERIOR	20/1	1.5		4.4		2.9		:	10
11	SPARE	20/1	0.0			2.9	2.9			12
13	SPARE	20/1	0.0	2.9			2.9	50/3	CP-2 (7.5 HP)	14
15	SPARE	20/1	0.0		2.9		2.9			16
17	SPARE	20/1	0.0			2.9	2.9			18
19	SPARE	20/1	0.0	1.3			1.3	20/3	TM-1 (3 HP)	20
21	SEPTIC TANK (1/3 HP)	15/1	0.9		2.2		1.3			22
23	AGITATOR (1.5 HP)	15/3	0.7			2.0	1.3			24
25	_	-	0.7	0.9			0.2	20/1	OWS CONTROL PANEL	26
27	_	_	0.7		1.4		0.7	15/1	WH-1 (1/4 HP)	28
29	DOOR 112A (1/2 HP)	20/1	1.2			2.9	1.7	25/1	CP-3 (3/4 HP), BM-1	30
31	DOOR 113A (1/2 HP)	20/1	1.2	2.7			1.5	20/3	EF-1 (1 HP)	32
33	DOOR 114A (1/3 HP)	15/1	0.9		2.4		1.5		<del></del>	34
35	DOOR 115A (1/2 HP)	20/1	1.2			2.7	1.5			36
37	CF-2, UH-3, UH-4	20/1	1.9	5.0			3.1	60/3	OVERHEAD CRANE, OC-1	38
39	CF-1, UH-1, UH-2	20/1	1.9		5.0		3.1			40
41	GRINDER PUMP (Panal A)	30/1	1.9			5.0	3.1			42
ВА	LANCED CONNECTED LOAD = 60.9 KVA / 169 AM	PS		18.6	21.1	21.2			BALANCED DEMAND LOAD = 0.0 KVA /	
М	AXIMUM CONNECTED LOAD = $60.9 \text{ KVA} / 177 \text{ AM}$	PS	-			· ATT	•	<del>,</del>	MAXIMUM DEMAND LOAD = 0.0 KVA /	

*	HID	CIRCUIT	BREAKER
	1110	CITCOLL	

			MEC	CHA	NIC	AL	E	QUIF	MENT SCH	DUL	E.			
	DESIGNATION				LOAD				CIRCUITING				CON.	TROL
ITEM	DESCRIPTION	LOCATION	110	LW	VOL TC	DUAGE		547116	00101107000	DISCO	NNECT			
IIEM	DESCRIPTION	LOCATION	HP	KW	VOLIS	PHASE	NO.	RATING	CONDUCTORS	SWITCH	FUSE	STARTER	CONTROL	REMARKS
CP-1	UREA PUMP	RM 111	7.5	-	208	3	_	50/3	3 NO. 8, 1 NO. 10	HD	_	1	ON-OFF	
CP-2	UREA PUMP	RM 111	7.5	_	208	3	_	50/3	3 NO. 8, 1 NO. 10	HD	-	1	ON-OFF	
CP-3	TANK HEATER PUMP	RM 111	3/4	_	120	1	-	25/1	2 NO. 10	HD	-	00	ON-OFF	
TM-1	PROPELLER MIXER	RM 111	3	_	208	3	-	20/3	4 NO. 12	HD	-	0	ON-OFF	1000
WH-1	WATER HEATER	RM 111	1/4	_	120	1	_	15/1	2 NO. 12	_	9	00	SWE	
BM-1	BAG MASSAGER	RM 111	0	_	120	1	_	20/1	2 NO. 12	GD	_	00	ON-OFF	
AG-1	AGITATOR	RM 111	1.5	_	208	3	_	15/3	4 NO. 12	GD	-	00	ON-OFF	
UH-1	UNIT HEATER	RM 115	1/3	_	120	1	-	20/1	2 NO. 12	GD	-	00	ON-OFF	
CF-1	CEILING FAN	RM 115	_	0.16	120	1	_	20/1	2 NO. 12	SW	_	00	SWF	MOUNT CNTLS ON MB
EF-1	EXHAUST FAN	RM 115	1	_	208	3	-	20/3	4 NO. 12	GD	_	00	VFD	
OC-1	OVERHEAD CRANE	RM 111	T -	-	208	3	-	60/3	3 NO. 6, 1 NO. 10 GND	HD	_	_	SWC	
CF-2	CEILING FAN	RM 115	_	0.16	120	1	-	20/1	2 NO. 12	SW	_	00	SWF	MOUNT CNTLS ON MB
UH-2	UNIT HEATER	RM 115	1/3	_	120	1	_	20/1	2 NO. 12	GD	_	00	ON-OFF	
UH-3	UNIT HEATER	RM 115	1/3	_	120	1	-	20/1	2 NO. 12	GD	-	00	ON-OFF	11-2
UH-4	UNIT HEATER	RM 114	1/3	_	120	1	-	20/1	2 NO. 12	GD	_	00	ON-OFF	
ows	OIL/WATER SEPARATOR	RM 114	_	-	120	1	-	20/1	2 NO. 12	SW	_	-	SWP	MOUNT CNTLS ON MB
	GRINDER PUMP	EXT	1	_	120	1	_	30/1	2 NO. 10	GD		-	SWP	MOUNT CNTLS ON EXT
	DOOR 106A	RM 106	1/2	_	120	1	_	20/1	2 NO. 12	GD	_	00	SWO	FEED FROM PANEL A
	DOOR 113A	RM 113	1/2	_	120	1	-	20/1	2 NO. 12	GD	_	00	SWO	
no communication and agree agree	DOOR 114A	RM 114	1/3		120	1	-		2 NO. 12	GD	_	00	SWO	
	DOOR 115A	RM 115	1/2	-	120	1	-	20/1	2 NO. 12	GD	-	00	SWO	
	DOOR 112A	RM 112	1/2	-	120	1	-	20/1	2 NO. 12	GD	_	00	SWO	
	SEPTIC TANK	OUTSIDE	1/3	_	120	1	_	15/1	2 NO. 12, 1 NO. 12 GND	GD	_	00	<b>1</b> -	
OP-1	FUEL OIL PUMP	RM 103	1/4	_	120	1	_	15/1	2 NO. 12	GD	_	00	ON-OFF	FEED FROM PANEL B

HD = HEAVY DUTY
GD = GENERAL DUTY
SW = SWITCH


SWE = SUPPLIED WITH EQUIPMENT SWP = SUPPLIED WITH PUMP SWF = SUPPLIED WITH FAN SWO = SUPPLIED WITH OPERATOR SWC = SUPPLIED WITH CRANE



#### NOTE:

- INSTALL NEW TALKBACK INTERCOM HEADEND EQUIPMENT IN ARFF BUILDING. TIE TO EXISTING TELEPHONE CABINET.
- INSTALL NEW TELEPHONE IN VEHICLE BAY 115.
- INSTALL TWO PAGING SPEAKERS EACH IN VEHICLE BAY 115 AND EXISTING GARAGE 106.
- INSTALL ONE PAGING SPEAKER IN SHOP OF ARFF BUILDING.
- 5. EXISTING HANDSET SYSTEM IS MERIDIAN.

TELEPHONE RISER



PATH:


BY: DATE: DESCRIPTION OF CHANGE:

RECORD OF REVISIONS

STATE OF ALASKA
DEPARTMENT OF TRANSPORTATION
AND PUBLIC FACILITIES
SOUTHEAST REGION

WRANGELL AIRPORT

SAND & CHEMICAL STORAGE BUILDING ADDITION



Jensen

522 West 10th Street

Juneau, Alaska 99801

NOTE:

phone 907-586-1070

fax 907-586-3959 jensenyorbalott.com

Yorba

Lott

